



CITY COUNCIL AGENDA FORM

Meeting Date: June 13, 2022

Agenda item: _____

Prepared by: R. Sailler

Reviewed by: _____

Department: Public Works

AGENDA ITEM DESCRIPTION: Discussion/possible action regarding ratification of an emergency expenditure to Atlas Copco for the cost of repairs to the blowers at the Wastewater Treatment Plant, in the amount of \$55,460.95

ATTACHMENTS FOR REFERENCE

- Quote

STAFF BRIEFING:

- We have two blowers for the Aeration Basins at the Wastewater Treatment Plant; we must have a redundant unit available at all times.
- The Aeration Basin are the main treatment process at an activated sludge at the Wastewater Treatment Plant without air (blowers) the microorganisms (bugs) we use to treat the water will become inactive or even die, causing a catastrophic breakdown of the treatment process.
- The Atlas Copco Blowers are property machines and we must use the manufacturer's designated repair vendor.
- The Blower which we are repairing experienced a severe maintenance related issue and must be repaired as soon as possible.

Has City authorized Engineer reviewed and approved?

N/A

Has City Attorney OR Special Legal Counsel reviewed and approved?

N/A

Have you discussed availability of funds/accounts with Finance Director?

Has Finance Director verified Purchasing Policy followed?

Yes

Have you presented your project to the Grants Administration Team and City Manager?

N/A

HISTORY:

- May 11, 2022 Blower#2 failed at the Wastewater Treatment Plant
- May 12, 2022 Purchase Order processed for emergency expenditure

TARGET IMPLEMENTATION: June 13, 2022



CITY COUNCIL AGENDA FORM

SIGNIFICANT ACTION DATES: May 12, 2022 - Purchase Order Generated

ACTION:

- | | |
|--|---|
| <input type="checkbox"/> Ordinance | <input type="checkbox"/> Resolution |
| <input type="checkbox"/> Special Presentation | <input type="checkbox"/> Proclamation |
| <input type="checkbox"/> Finance Report | <input type="checkbox"/> Public Hearing |
| <input type="checkbox"/> Municode Codification | |
| <input checked="" type="checkbox"/> Mark if this item does not conflict with any Resolution, Ordinance or City Charter, policies, procedures | |

Cost Details:	
Budgeted	
Actual Bid	
Estimated Expenditure	\$55,460.95
Acct. Name(s)	Repair & Maint Sewer Treatment Plant
Line Items #	02-3010-24-00
Other Funding	

STAFF'S RECOMMENDATION: Motion to ratify emergency expenditure to Atlas Copco for the cost of repairs to Blower #2 at the Wastewater Treatment Plant, in the amount of \$55,460.95

FISCAL IMPACT: None